

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1111

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1349 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-Tec)
Challenge Way
Martland Park
Wigan
WN5 0LD
United Kingdom

Computationics Limited (trading as C-Tec)
Challenge Way
Martland Park
Wigan
WN5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power Supply Equipment
EN 12094-1:2003 - Components for Gas Extinguishing Systems - Requirements and Test Methods for Electrical Automatic Control and Delay Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



E. Mattie-Suleiman, Technical Development Director

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 23 May 2023

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1111

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

Incorporating the following units:

SPF0000203 Main extinguisher control
SPF0000212 External relay interface
SPF0361021 Power supply unit
SPF0000214 EP214 Terminal

Certified with the following options with the requirements from EN 12094-1:2003:

- 4.17 Delay of extinguisher signal
- 4.18 Signal representing the flow of extinguishing agent
- 4.19 Monitoring of the status of components
- 4.20 Emergency hold device
- 4.21 Control of flooding time
- 4.23 Manual only mode
- 4.26 Triggering of equipment outside the system
- 4.27 Emergency abort device
- 4.30 Activation of alarm devices with different signals

Certified with the following options with requirements from EN 54-2:1997:

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment
- 7.13 Alarm counter
- 10 Test condition

Notes:

1. The following modules are ancillaries that are permitted to be connected to the e.c.d. as optional modules but are not tested or approved to any standard(s)
 - EP210S Remote Status Unit "Surface Mount" optional
 - EP210F Remote Status Unit "Flush Mount" optional
 - EP211 Economy Status Unit optional
 - EP215 Emergency Hold/Abort
2. The e.c.d. meets the requirements of EN 12094-1:2003, Class A – i.e. operational temperature range of -5°C to + 40°C.



E. Mattie-Suleiman, Technical Development Director

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 23 May 2023

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1111

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

3. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN 54-13.



E. Mattie-Suleiman, Technical Development Director

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 23 May 2023

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com