

## Certificate of Product Approval

Certificate Number: 330n

Issue: 04

### Zeta Alarms Limited

Detection House  
72-78 Morfa Road  
Swansea  
SA1 2EN  
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Smoke Detectors

MKII-OP  
MKII-AOP  
(refer to Appendix for details)

#### Standards

**EN 54-7:2000 + A1:2002 + A2:2006**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

14 June 2017

Date of Issue

10 May 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 330n Zeta Alarms Limited

Issue: 04

Certified Product	Description	LPCB Ref.No.
MKII-OP	Fyreye II Conventional Optical Smoke Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-7:2000 at smoke sensitivity setting range: 0.08%dB ~ 0.12%dB	330n/01
MKII-AOP	Fyreye II Addressable Optical Smoke Detector (MKII-CB/D Base and MKII-CB Base) Note: 1. Meets the requirements of EN 54-7:2000 at smoke sensitivity setting range: 0.09%dB ~ 0.11%dB	330n/02

### Bases

MKII-CB/D      **Deep Base**  
MKII-CB        **Shallow Base**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
Verifier

14 June 2017  
Date of Issue

10 May 2013  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.


