

Declaration of Performance – DOP0000042UK

According to the Construction Products (Amendment etc.) (EU Exit) Regulations 2020

1. Unique Product identification code(s):

BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR

2. Type, batch or serial number(s) or any other element allowing identification of the construction product(s) as required pursuant to Article 11(4):

Compact 91dB(A) Ceiling / Wall Sounder, white plastic housing (BF450A/CX/SW)
Compact 91dB(A) Ceiling / Wall Sounder, red plastic housing (BF450A/CX/SR)
Compact C-3-8 / W-3-3.1 VAD c/w 91dB(A) sounder, white plastic housing (BF451A/CX/SW)
Compact C-3-8 / W-3-3.1 VAD c/w 91dB(A) sounder, red plastic housing (BF451A/CX/SR)
Compact C-3-8 / W-3-3.1 VAD only, white plastic housing (BF458A/CX/SW)
Compact C-3-8 / W-3-3.1 VAD only, red plastic housing (BF458A/CX/SR)

3. Intended use or uses of the construction product(s), in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR:

Sounders to BS EN 54-3: 2001 for use in Fire detection and fire alarm systems in buildings

Models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:

Short-circuit isolators to BS EN 54-17: 2005 for use in Fire detection and fire alarm systems in buildings

Models BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:

Visual alarm devices to BS EN 54-23: 2010 for use in Fire detection and fire alarm systems in buildings

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Computationics Limited (C-TEC)
Challenge Way, Martland Park, Wigan, WN5 0LD. United Kingdom
Tel: 01942 322744. Fax: 01942 829867

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. Notified body, in the case of the declaration of performance concerning a construction product covered by a harmonized standard:

Intertek Testing & Certification Limited (UK Approved Body Number 0832)
Intertek House, Cleeve Road, Leatherhead,
Surrey KT22 7SB. United Kingdom.

has performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance / certificate of conformity:

0359-UKCA-CPR-00124

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: Not applicable, see item 7

9(a). Declared performance applicable to models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the British Standard mentioned in the following table.

Technical Specification		BS EN 54-3: 2001+ A1: 2002+ A2: 2006
Essential Characteristics	Performance	Clause
Performance parameters under fire condition		
- Sound level	Pass	4.2
- Frequency and sound patterns	Pass	4.3
- Reproducibility	Pass	5.2
- Operational performance	Pass	5.3
- Attention drawing signal and message broadcast sequences	NPD	C.3.1
- Synchronisation (option with requirements)	NPD	C.3.2
- Broadcast message performance	NPD	C.5.1
- Attention-drawing signal silence message sequence timing	NPD	C.5.2
- Message synchronisation testing option with requirements	NPD	C.5.3
Operational reliability		
- Durability	Pass	4.4
- Construction	Pass	4.5
- Marking and data	Pass	4.6
- Durability	Pass	5.4
- General testing	NPD	C4
Durability of operational reliability		
Temperature resistance:		
- Dry heat (operational)	Pass	5.5
- Dry heat (endurance)	Pass	5.6
- Cold (operational)	Pass	5.7
- Damp heat, cyclic (operational)	Pass	5.8
- Damp heat, steady state (endurance)	Pass	5.9
Humidity resistance:		
- Damp heat, cyclic (operational)	Pass	5.8
- Damp heat, steady state (endurance)	Pass	5.9
- Damp heat, cyclic (endurance)	Pass	5.10
Corrosion resistance:		
- Sulfur dioxide (SO ₂) corrosion (endurance)	Pass	5.11
Shock and vibration resistance:		
- Shock (operational)	Pass	5.12
- Impact (operational)	Pass	5.13
- Vibration, sinusoidal (operational)	Pass	5.14
- Vibration, sinusoidal (endurance)	Pass	5.15
Electrical stability:		
- Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.16
Resistance to ingress:		
- Enclosure protection	Pass	5.17
Meets the requirements of BS EN 54-3 for the following (operating voltage range 17-28 VDC):		
Tone 1 - Primary		
- Evacuate, 550Hz for 0.5s, 825Hz for 0.5s		
- Alternating, 925Hz for 0.25s, 626Hz for 0.25s		
- Dutch slow sweep, 500Hz to 1200Hz for 3.5s on, 0.5s off		

9(b). Declared performance applicable to models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the British Standard mentioned in the following table.

Technical Specification		BS EN 54-17: 2005
Essential Characteristics	Performance	Clause
Performance under fire conditions - Reproducibility ⁽¹⁾	Pass	5.2
Operational reliability - General requirements	Pass	4
Durability of operational reliability (temperature resistance) - Dry heat (operational) - Cold (operational)	Pass Pass	5.4 5.5
Durability of operational reliability (vibration resistance) - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance)	Pass Pass Pass Pass	5.9 5.10 5.11 5.12
Durability of operational reliability (humidity resistance) - Damp heat, cyclic (operational) - Damp heat, steady state (operational)	Pass Pass	5.6 5.7
Durability of operational reliability (corrosion resistance) - Sulphur dioxide (SO ₂) corrosion (endurance)	Pass	5.8
Durability of operational reliability (electrical stability) - Variation in supply voltage - Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass Pass	5.3 5.13

⁽¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices.

9(c). Declared performance applicable to models BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the British Standard mentioned in the following table.

Technical Specification		BS EN 54-23: 2010
Essential Characteristics	Performance	Clause
Operational reliability - Duration of operation - Provision for external conductors - Flammability of materials - Enclosure protection - Access - Manufacturer's adjustments - On-site adjustment of behaviour - Requirements for software controlled devices	Pass Pass Pass Pass Pass Pass Pass Pass	4.2.1 4.2.2 4.2.3 4.2.4 4.2.5 4.2.6 4.2.7 4.2.8
Performance parameters under fire condition - Coverage volume - Variation of light output - Minimum and maximum light intensity - Light colour - Light temporal pattern and frequency of flashing - Marking and data - Synchronisation (option with requirements)	Pass Pass Pass White Pass/0.5Hz Pass Pass	4.3.1 4.3.2 4.3.3 4.3.4 4.3.5 4.3.6 4.3.7
Durability Temperature resistance: - Dry heat (operational) - Dry heat (endurance) - Cold (operational) Humidity resistance: - Damp heat, cyclic (operational) - Damp heat, steady state (endurance) - Damp heat, cyclic (endurance) Shock and vibration resistance: - Shock (operational) - Impact (operational) - Vibration (operational) - Vibration (endurance) Corrosion resistance: - SO2 corrosion (endurance) Electrical stability: - EMC, immunity (operational)	Pass NPD Pass Pass Pass NPD Pass Pass Pass Pass Pass Pass	4.4.1.1 4.4.1.2 4.4.1.3 4.4.2.1 4.4.2.2 4.4.2.3 4.4.3.1 4.4.3.2 4.4.3.3 4.4.3.4 4.4.4 4.4.5
Meets the requirements of BS EN 54-23 for the following: - Category C-3-8 or W-3-3.1 - Flash rate 0.5Hz - Synchronisation - Operating voltage range 21-28 VDC		

10. Empowered Signatory of Company

Name: Daniel Foster
 Position: Head of Science
 Signature: 
 Date: 15th August 2022