



Kitemark™ Certificate

This is to certify that:

Zeta Alarms Limited Detection House 72-78 Morfa Road Swansea SA1 2EN United Kingdom

Holds Certificate Number:

KM 609616

In respect of:

BS EN 54-2, BS EN 54-4 & BS EN 12094-1 Control and Indicating Equipment and Power Supply Equipment, Electrical Automatic Control and Delay Devices for Gas Extinguishing Systems

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 23/03/2017

Latest Issue: 23/03/2017

Ø

Page: 1 of 2

...making excellence a habit."

Kitemark™ Certificate

No. KM 609616

BS EN 12094-1:2003, BS EN 54-2:1997 and BS EN 54-4:1998 + A1

Model Reference

Type

Prem1er EXPRO

Class A, Two Zone, Single Area Extinguishing Control Panel

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997:

Output to fire alarm devices (clause 7.8) Test condition (clause 10)

Certified with the following options with requirements from BS EN 12094-1:2003:

Delay of extinguishing signal (clause 4.17)
Signal representing the flow of extinguishing agent (clause 4.18)
Control of flooding time (clause 4.21)
Manual only mode (clause 4.23)
Emergency abort device (clause 4.27)

First Issued: 23/03/2017 Latest Issue: 23/03/2017

Page: 2 of 2