


MEERSBROOK

MEERSBROOK LED 5 in 1 Exit Sign, 3.2V LiFePO4 Battery, Self Test























GENERAL DATA

| | L | Light Source |
|--------------|---|--------------------------------------|
| | 1 | Light Source Replaceable |
| | \ | Colour/Finish |
| | F | Material |
| | | IP Rating |
| | | IK Rating |
| / Wall Mount | (| Mounting Type |
| | 1 | Warranty (Years) |
| | 1 | Life Time Hours |
| _ | | Life Time Hours DIMENSIONS & WEIGHT |

| Width (mm) | 344 |
|-------------|------|
| Depth (mm) | 42 |
| Height (mm) | 237 |
| Weight (g) | 1556 |

BLE LIGHTING AND POWER LTD



ELECTRICAL

| ELECTRICAL | |
|---------------------------------|---------------------------------|
| Input Voltage (V) | 220-240 |
| Input Frequency (Hz) | 50 |
| Wattage (W) | 2.8 |
| Classification | Class I |
| Operating Temperature (°C) | 0 to +40 |
| Power Factor | 0.56 |
| OPTICAL | |
| Colour Temperature | 6500K |
| CRI | 70 |
| Beam Angle (°) | 96 |
| Lumen Output Mains (lm) | 37 |
| Viewing Distance (M) | 29 |
| EMERGENCY | |
| Battery Type | LiFePO4 18650 3.2V |
| Battery Capacity | 1.5Ah |
| Battery Warranty (Years) | 5 |
| Recharge Time (hrs) | 24 |
| Battery Replaceable | Yes |
| Mode of Operation | Maintained / Non-maintained |
| Test Procedure | Self Test |
| Emergency Duration (hrs) | 3 |
| Lumen Output Emergency (lm) | 27 |
| STANDARDS & APPROVALS | |
| Manufactured in Accordance with | BS EN 60598-1, BS EN 60598-2-22 |
| CE Mark | Yes |
| UKCA Mark | Yes |
| WEEE Symbol | Yes |
| Accredited Members | ISO 9001, ISO 14001 |
| PACKAGING | |
| Packaging Length (mm) | 390 |
| | |

BLE LIGHTING AND POWER LTD

DATA SHEET EL-131950



| Packaging Width (mm) | 240 |
|----------------------|-----|
| Packaging Depth (mm) | 87 |

BLE LIGHTING AND POWER LTD