

Declaration of Performance –
No: RSL-R-0402-CPR-SC0226-14

Roof Single Leaf – Residential (RSL-R)

Description	Details
1. Product Type: Unique identification code of the product-type	Roof Single Leaf – Residential (RSL-R) Natural smoke and heat exhaust ventilator.
2. Type: Batch or serial number or any other element allowing identification of the construction product as required under Article 11(4)	RSL-R – for Batch Number see Product labeling
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer	Dual purpose ventilator, intended for comfort ventilation as well as smoke and heat exhaust ventilation under fire conditions
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5)	RSL-R SERTUS Europa House, Alfold Road Cranleigh GU6 8NQ hello@sertus.uk
5. Contact Address: Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified on Article 12(2)	Not applicable
6. AVCP: System or systems of assessment and verification of constancy of performance (AVCP) of the construction product as set out in CPR, Annex V	AVCP System 1
7. Notified body (hEN): In case of the declaration of performance (DoP) concerning a construction product covered by a harmonised standard	Notified Body No. 0402 RISE Research Institutes of Sweden Box 857, SE-501 15 Borås, Sweden
8. Notified body (ETA): In case of the declaration of performance concerning a construction product for which a European Technical Assessment (ETA) has been issued:	Not applicable (see 7)



EN12101-2:2003

Roof Single Leaf – Residential (RSL-R)


9. Declared performance

Essential Characteristics	Performance	Harmonised Standard
Fire Rating Internal External	B-s3, d0 $B_{ROOF}(t_4)$	EN 13501-1 EN 13501-5
Resistance to Heat	B300	EN 12101-2:2003 Annex G
Snow Load	SL 500 (max 3000 x 2200mm) SL1000 (max 2400 x 1600mm)	EN 12101-2:2003 Annex D
Wind Load	WL 1500 (with offset motors – WL 1000)	EN 12101-2:2003 Annex F
Low Ambient Temperature	T (-15)	EN 12101-2:2003 Annex E
Reliability	Re 1000	EN 12101-2:2003 Annex C
Aerodynamic Free Area	See tables 1 & 2 For sizes not covered by tables $C_v = 0.40$	EN 12101-2:2003 Annex B
Dangerous Substances	No dangerous substances above the acceptable limits	N/A

10. Declaration

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance (DoP) is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Steve Knight, Technical Director

Cranleigh, March 2019



EN12101-2:2003

Roof Single Leaf – Residential (RSL-R)

Table 1: Vertical Curb, PVC 150V upstand, 160° opening angle

C	B	Geometric Area	Free Area	Aerodynamic Values				Snow Load*
Roof Opening PVC150V	Daylight Size			Standard		With Spoilers		
(mm)	(mm)	(Av)	(m²)	(Cv)	(Aa)	(Cv)	(Aa)	(N/m²)
1000 × 1000	1000 × 1000	1.00	0.90	0.55	0.55	0.61	0.61	1000
1050 × 1050	1050 × 1050	1.10	1.00	0.55	0.61	0.61	0.67	1000
1100 × 1100	1100 × 1100	1.21	1.11	0.55	0.67	0.61	0.74	1000
1200 × 1200	1200 × 1200	1.44	1.34	0.55	0.79	0.61	0.88	1000
1300 × 1300	1300 × 1300	1.69	1.59	0.55	0.93	0.61	1.03	1000
1000 × 1300	1000 × 1300	1.30	1.20	0.55	0.72	0.61	0.79	1000
1000 × 1500	1000 × 1500	1.50	1.40	0.54	0.81	0.61	0.92	1000
1000 × 1600	1000 × 1600	1.60	1.50	0.53	0.85	0.61	0.98	1000
1000 × 1900	1000 × 1900	1.90	1.80	0.52	0.99	0.62	1.18	1000
1000 × 2000	1000 × 2000	2.00	1.90	0.52	1.04	0.62	1.24	1000
1000 × 2200	1000 × 2200	2.20	2.10	0.52	1.14	0.62	1.36	500
1000 × 2300	1000 × 2300	2.30	2.20	0.52	1.20	0.62	1.43	500
1050 × 1650	1050 × 1650	1.73	1.63	0.52	0.90	0.61	1.06	1000
1050 × 2250	1050 × 2250	2.36	2.26	0.51	1.20	0.62	1.46	500
1100 × 1400	1100 × 1400	1.54	1.44	0.53	0.82	0.61	0.94	1000
1100 × 1700	1100 × 1700	1.87	1.77	0.53	0.99	0.62	1.16	1000
1100 × 2300	1100 × 2300	2.53	2.43	0.52	1.32	0.62	1.57	500
1200 × 1400	1200 × 1400	1.68	1.58	0.52	0.87	0.61	1.02	1000
1200 × 1500	1200 × 1500	1.80	1.70	0.54	0.97	0.61	1.10	1000
1200 × 1800	1200 × 1800	2.16	2.06	0.53	1.14	0.61	1.32	500
1200 × 2100	1200 × 2100	2.52	2.42	0.52	1.31	0.62	1.56	500
1300 × 1600	1300 × 1600	2.08	1.98	0.53	1.10	0.61	1.27	500
1300 × 1900	1300 × 1900	2.47	2.37	0.53	1.31	0.62	1.53	500
1300 × 2000	1300 × 2000	2.60	2.50	0.51	1.33	0.62	1.61	500
1300 × 2200	1300 × 2200	2.86	2.76	0.51	1.46	0.62	1.77	500
1300 × 2300	1300 × 2300	2.99	2.89	0.51	1.52	0.62	1.85	500

* with offset motors the Snow Load should be reduced to SL 500



EN12101-2:2003

Roof Single Leaf – Residential (RSL-R)

Table 2: Splayed Curb, PVC 300S upstand, 160° opening angle

C	B	Geometric Area	Free Area	Aerodynamic Values				Snow Load*
Roof Opening PVC300S	Daylight Size			Standard		With Spoilers		
(mm)	(mm)	(Av)	(m²)	(Cv)	(Aa)	(Cv)	(Aa)	(N/m²)
1200 x 1200	1000 x 1000	1.44	1.34	0.47	0.68	0.57	0.82	1000
1250 x 1250	1050 x 1050	1.56	1.46	0.47	0.73	0.57	0.89	1000
1300 x 1300	1100 x 1100	1.69	1.59	0.48	0.81	0.58	0.98	1000
1400 x 1400	1200 x 1200	1.96	1.86	0.49	0.96	0.59	1.16	1000
1500 x 1500	1300 x 1300	2.25	2.15	0.49	1.10	0.59	1.33	1000
1200 x 1500	1000 x 1300	1.80	1.70	0.49	0.88	0.59	1.06	1000
1200 x 1700	1000 x 1500	2.04	1.94	0.50	1.02	0.60	1.22	1000
1200 x 1800	1000 x 1600	2.16	2.06	0.50	1.08	0.60	1.30	1000
1200 x 2100	1000 x 1900	2.52	2.42	0.51	1.29	0.61	1.54	1000
1200 x 2200	1000 x 2000	2.64	2.54	0.51	1.35	0.61	1.61	1000
1200 x 2400	1000 x 2200	2.88	2.78	0.51	1.47	0.62	1.79	500
1200 x 2500	1000 x 2300	3.00	2.90	0.52	1.56	0.63	1.89	500
1250 x 1850	1050 x 1650	2.31	2.21	0.50	1.16	0.60	1.39	1000
1250 x 2450	1050 x 2250	3.06	2.96	0.51	1.56	0.62	1.90	500
1300 x 1600	1100 x 1400	2.08	1.98	0.50	1.04	0.60	1.25	1000
1300 x 1900	1100 x 1700	2.47	2.37	0.50	1.24	0.60	1.48	1000
1300 x 2500	1100 x 2300	3.25	3.15	0.52	1.69	0.63	2.05	500
1400 x 1600	1200 x 1400	2.24	2.14	0.51	1.14	0.61	1.37	1000
1400 x 1700	1200 x 1500	2.38	2.28	0.51	1.21	0.61	1.45	1000
1400 x 2000	1200 x 1800	2.80	2.70	0.51	1.43	0.62	1.74	500
1400 x 2300	1200 x 2100	3.22	3.12	0.52	1.67	0.63	2.03	500
1500 x 1800	1300 x 1600	2.70	2.60	0.53	1.43	0.64	1.73	500
1500 x 2100	1300 x 1900	3.15	3.05	0.51	1.61	0.62	1.95	500
1500 x 2200	1300 x 2000	3.30	3.20	0.52	1.72	0.63	2.08	500
1500 x 2400	1300 x 2200	3.60	3.50	0.53	1.91	0.64	2.30	500
1500 x 2500	1300 x 2300	3.75	3.65	0.54	2.03	0.65	2.44	500

* with offset motors the Snow Load should be reduced to SL 500



EN12101-2:2003